

Table of Standard Loss Adjustment Factors 2009/10

SP Manweb Loss Adjustment Factors		Night	Other	Winter Weekday	Winter Peak	LLFC
		Period 1	Period 2	Period 3	Period 4	
Import	LV Non Half Hourly and LV Network Connected	1.076	1.091	1.103	1.117	101, 102, 103, 104, 105, 106, 111, 112, 113, 114, 115, 116, 117, 118, 119, 120, 131, 132, 133, 134, 135, 136, 137, 138, 140, 141, 142, 143, 145, 146, 147, 148, 149, 150, 153, 155, 201, 202, 203, 205, 211, 212, 231, 232, 233, 234, 235, 236, 237, 900, 901, 902, 903, 904, 905, 906, 907, 910, 912, 913, 401, 402, 501, 511, 591
	LV Substation connected	1.055	1.060	1.065	1.071	207, 208, 209, 210, 403, 404, 503, 592, 513
	HV Network connected	1.032	1.039	1.044	1.049	405, 505, 515, 593
	HV Substation connected	1.023	1.027	1.030	1.032	507, 594, 517
	33kV generic	1.015	1.018	1.020	1.022	Site specific
	132kV generic	1.004	1.005	1.006	1.007	Site specific
Export	LV NHH and LV Network connected	1.076	1.091	1.103	1.117	781-785, 791, 795
	LV Substation connected	1.055	1.060	1.065	1.071	792, 796
	HV Network connected	1.032	1.039	1.044	1.049	793, 797
	HV Substation connected	1.023	1.027	1.030	1.032	794, 798
	33kV generic	1.015	1.018	1.020	1.022	Site specific
	132kV generic	1.004	1.005	1.006	1.007	Site specific

Notes on the Table

- a. Times given are Clock times. Time periods are defined as follows:

Period 1	Night	23.30-07.30	All Year
Period 2	Other	Any time outwith Periods 1, 3, 4	
Period 3	Winter Weekday	07.30-16.00	Mon-Fri 1 Nov - 28 Feb
		19.00-20.00	Mon-Fri 1 Nov - 28 Feb
Period 4	Winter Weekday Peak	16.00-19.00	Mon-Fri 1 Nov - 28 Feb

All times are clock times